



Confirmation

eurofins

Eurofins Product Testing A/S confirms that a sample of a cement based levelling compound with the name

UZIN MK 200

supplied by

Uzin Utz AG

showed low VOC emissions in a test in accordance with the “*Standard Method for the Testing and Evaluation of VOC Emissions from Indoor Sources using Environmental Chambers, version 1.1 of February 2010 by the California Department of Public Health*”, as specified in indoor air emission criteria of Collaborative for High Performance Schools (CHPS), Indoor Advantage Gold TN certification, Floorscore and LEED (2009) credit 4.3 (Low-emitting materials - flooring systems) and LEED v4 credit EQc2 (Low-emitting materials).

Emissions were below all limit values specified in that standard practice.

The test has been performed in February 2014, see test report no. 392-2014-00018601. The testing methodology is covered by independent ISO 17025 accreditation, issued by DANAK (# 522).

With this confirmation, use of product may qualify for fulfillment of LEED (2009) credit 4.3 / LEED v4 credit EQc2 (Low-emitting materials).

06 March 2014

Thomas Neuhaus
Head of product emission test centre

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com